



# Pragathi Krishna Gramin Bank

(A Scheduled Bank owned by Government of India, Karnataka)

Sponsored by Canara Bank

GA Wing, Head Office, Ballari)

Ph:08392-236461; 236465 e-mail : [psitw.itd@pkgbank.com](mailto:psitw.itd@pkgbank.com)

**RFP : Rate Contract for supply, installation, commissioning and maintenance of 3KVA & 5 KVA UPS with Batteries and without Batteries for our Bank Branches/Administrative Offices across 11 districts of Karnataka state.**

**REF : PKGB/GAW/02/2018-19 dated 27.06.2018**

## ADDENDUM 1

### Introduction :

The Bank had issued the Request for Proposal (RFP) No. PKGB/GAW/02/2018-19 dated 27.06.2018 inviting offers from Empanelled Vendors of the Bank for Supply, Installation, Commissioning and Maintenance of 3KVA & 5 KVA UPS with batteries and without batteries to Bank branches/Administrative Offices across 11 districts of Karnataka state on Rate Contract basis.

This response covers clarifications to the queries raised by the vendors via e-mail and during pre-bid meeting held on 13.07.2018. Further, other additional information which Bank considers essential to be informed to the vendors for better understanding is also included. All efforts have been made to provide maximum available information and answer all appropriate questions forwarded by the vendors.

All appropriate questions have been answered in this Addendum1 and all repetitions have been ignored. Further, additional clause has been added with respect to submission of EMD. All other terms and conditions of the RFP document remain unchanged. Please treat this addendum as an integral part of the RFP documents issued.

**THE LAST DAY AND TIME FOR BID SUBMISSION DATE IS MODIFIED: 26<sup>TH</sup> JULY 2018 (THURSDAY) 3.00 PM. THE BIDS WILL BE OPENED AT 3.30 P.M. ON THE SAME DAY.**

**Date : 19-07-2018**

**GENERAL MANAGER**

Annexure 1– The following Annexure included in this addendum replace the corresponding Annexure in the RFP

Annexure 2 – Bill of Material – Annexure G of RFP

**Annexure 1**

<b>Sl.</b>	<b>Page No./ Clause No.</b>	<b>Existing clause</b>	<b>Query/ remarks from the vendors</b>	<b>Bank's Reply</b>
1	Page 2 &  Page 11	Non-refundable cost Bid of Rs. 1,000/- (Rupees One thousand only) by way of Demand Draft favouring Pragathi Krishna Gramin Bank, HO, Ballari	Request for exemption of Non-refundable cost of Bid of Rs. 1,000/- to be paid while submitting Bid documents being NSIC registration and MSME registration firms. (Enclosed copy of NSIC certificate and MSME (SSI) certificate for your reference.	Bidder to comply with terms of the RFP
2	Page 2 & Page 10	EMD/Bank Guarantee valid for 12 months issued 12 months by any Scheduled Bank for Rs. 4,00,000/- (Rupees Four lakh only) to be submitted along with the Bid documents	Request for exemption for EMD/Bank Guarantee to be submitted along with Bid documents as NSIC Registration and MSME (SSI) Certificate enclosed	The clause is amended as below :- EMD/Bank Guarantee valid for 12 months issued by any Scheduled Bank for Rs. 4,00,000/- (Rupees Four lakh only) to be submitted along with the Bid documents.  However, if the Vendor submits a valid certificate of NSIC registration and MSME (SSI) certificate, the EMD/Bank Guarantee shall be waived.
3	Page No.27 Sl. No. 4 of Annexure F1 of RFP	Input Voltage Range is to be single phase 3-wire with 150V to 300 V, single phase	The Input Voltage Range required as per your RFP is very long range. Request to consider from 170 to 270V single phase. Otherwise, you may procure the UPS with AVR	The clause is amended as below :- Input Voltage Range is to be single phase 3-wire with 150V to 270 V, single phase.
4	Page No.31 Sl. No. 4 of Annexure F2 of RFP			

Sl.	Page No./ Clause No.	Existing clause	Query/ remarks from the vendors	Bank's Reply
5	Page No. 13, Point No. (ii)	If for any reason, the installation and commissioning is delayed due to non-readiness of infrastructure and hence acceptance certificate cannot be issued, the above 20% of the Total Contract price shall be paid within 90 days from the date of receipt of goods at the respective locations. In such a case, the supplier shall have to produce document showing "site not ready" status from the representative of Pragathi Krishna Gramin Bank at respective locations and to undertake to install and successfully commission the equipments within 15 days of confirmation of readiness of infrastructure by the Bank. This however, does not preclude the Bank from invoking the Performance Guarantee if warranted, as per the terms of this Bid document.	Requested to change the time period to 30 days from the date of delivery	Bidder to comply with terms of the RFP
6	Page 15	<b>Maintenance of UPS and Batteries</b> : On lodgment of complaint, service should be provided and rectification of reported problem within eight (8) hours in Semi-Urban/ Rural centre & within four (4) hours in Urban centers. In case any part is	On lodgment of complaint, service should be provided and rectification of reported problem within Twenty four (24) hours in Semi-Urban/ Rural centre & within Twelve (12) hours in Urban centers. In case any part is found defective & needs to be taken to the Vendor's Premises/lab for repairs, the	The clause is amended as below :-  <b>Maintenance of UPS and Batteries:</b> On lodgment of complaint, service should be provided and rectification of reported problem within Twenty four (24) hours in case of Rural centers & within Twelve (12) hours in case of Urban/Semi-Urban centres. In case any part is found defective & needs to be taken to

		found defective & needs to be taken to the Vendor's Premises/lab for repairs, the Vendor should either ensure the required parts is replaced or a standby equipment is provided in place of defective equipment within 24 hours or next business day.	Vendor should either ensure the required parts is replaced or a standby equipment is provided in place of defective equipment within 48 hours or next business day.	the Vendor's Premises/lab for repairs, the Vendor should either ensure the required parts is replaced or a standby equipment is provided in place of defective equipment within 24 hours or next business day.
7	Page 15	In case of failure of the vendor in both the above cases, the vendor will be liable for penalty of Rs.500/- per day in Urban Centers and Rs.250/- per day in Semi Urban / Rural centers subject to a maximum of 10% of the contract value. The amount of penalty will be recovered from the vendor from payments due to them or by invoking Bank Guarantees provided for warranty /maintenance. If the penalty amount reaches the maximum, Bank will be at liberty to cancel the contract and invoke all the Bank guarantees provided by the vendor. However, if the UPS Systems is down due to the reasons attribute to the Bank, the vendor has to submit proof for the same for not levying the penalty.	In case of failure of the vendor in both the above cases, the vendor will be liable for penalty of Rs.100/- per day in Urban Centers and Rs.50/- per day in Semi Urban / Rural centres subject to a maximum of 10% of the contract value.	<b>Maintenance of UPS and Batteries</b> The clause is amended as below :- In case of failure of the vendor in both the above cases, the vendor will be liable for penalty of Rs.200/- per day in Urban/Semi-Urban Centers and Rs.100/- per day in Rural centers subject to a maximum of 10% of the contract value. The amount of penalty will be recovered from the vendor from payments due to them or by invoking Bank Guarantees provided for warranty/maintenance. If the penalty amount reaches the maximum, Bank will be at liberty to cancel the contract and invoke all the Bank guarantees provided by the vendor. However, if the UPS Systems is down due to the reasons attributable to the Bank, the vendor has to submit proof for the same for not levying the penalty.

Sl.	Page No./ Clause No.	Existing clause	Query/ remarks from the vendors	Bank's Reply
8	Page 17	The L1 vendor shall agree to match the highest buyback price quoted among vendors under each category of old/existing UPS and batteries. The vendor shall take back old UPS and batteries (wherever ordered) under "as is where is" condition and at no extra cost to Bank.	L1 price should be considered after the buy-back value quoted by L1 Vendor, instead of matching highest price of the buy-back quoted by other empanelled vendor.	The clause is amended as below :- L1 price is considered on the basis of price of UPS/UPS and batteries less the buy-back amount of UPS/UPS and batteries quoted by each vendor. The vendor shall take back old UPS and batteries (wherever ordered) under "as is where is" condition and at no extra cost to Bank.
9	Page No.2	Last date for submission of bids is 20-07-2018 (Friday) up to 11.30 AM	We request to kindly extend the Bid submission date by one week.	The clause is amended as below :- Last date for submission of bids is 26-07-2018 (Thursday) up to 3.00 PM and opening of the bids will be made at 3.30 PM on the same day.
10	Page No. 9	<b>COST AND CURRENCY:</b>  1) The Price offered to the Bank must be in Indian Rupees. The cost of UPS and batteries must be inclusive of all Duties / Insurance / Freight and all applicable taxes in India like GST, CST / LST / VAT / Octroi / Entry Tax Etc.	GST should be extra instead of inclusive	The clause is amended as below :-  <b>COST AND CURRENCY:</b>  1) The Price offered to the Bank must be in Indian Rupees. The cost of UPS and batteries must be inclusive of all Duties / Insurance / Freight and all applicable taxes in India like CST / LST / VAT / Octroi / Entry Tax etc., and exclusive of GST.
11	Page No. 13. Sl No. (ii) & (iii)	<b>Payment Terms</b> i) <b>On Delivery:</b> Eighty (80) % of the Contract price of the Goods along with GST, Octroi, wherever applicable, on production of relevant documents. Please	Payment terms should be 90% against delivery and balance 10% after installation and acceptance instead of 80% against delivery and 20% against installation and acceptance.	Bidder to comply with terms of the RFP

		<p>note that Originals of Invoices (plus one copy) reflecting taxes and duties, proof of Delivery duly signed by bank officials of the respective branch/office should be submitted while claiming payment in respect of orders placed.</p> <p>ii) <b>On Final Acceptance:</b>  Twenty (20) % will be released after successful Installation, Commissioning and Acceptance Certificate issued by the Bank's representative. The invoice and installation report should contain the product serial number of the items supplied.</p>		
12	-	-	Whether matching of L2, L3 vendors with L1 vendor is there ? Please confirm.	Clarification :- Bank may consider splitting of the Order subject to the L1 vendor expressing inability to meet the Bank requirements in whole or in part within the time period specified.

Sl.	Page No./ Clause No.	Existing clause	Query/ remarks from the vendors	Bank's Reply
13	Annexure F1 – Technical specifications  Point No.3  Point No. 9	Operating Temperature 0 degrees to 50 degrees centigrade  150% Overload capacity for 60 seconds	Operating Temperature 0 to 40 degrees centigrade. For 50 degree centigrade depends on the capacity.  150% Overload capacity for 40 seconds	Bidder to comply with terms of the RFP.
14	Annexure F1 – Technical specifications  Sl. No.3  Sl. No 3	Noise level less than 50dB  Operating Temperature 0 degrees to 50 degrees centigrade	Less than 55 dB  Operating Temperature 0 to 40 degrees centigrade. For 50 degree centigrade depends on the capacity.	The clause is amended as below :-  Noise level less than 55dB is acceptable.  Bidder to comply with terms of the RFP.

In case any clarification not specified, it is to be read as **Bidder to comply with terms of the RFP.**